2 X 210 MW TENUGHAT TPS-DRY FLY ASH COLLECTION AND DISPOSAL SYSTEM						
SL No	Volume/Scetion	Clause No.	Page No	Tender specification	Queries/Clarification	TVNL's response
34	General				BHEL requests customer to provide 2nos 6.6KV power feeders near to Main silo location for feeding of MCC	Confirmed.
35	General				BHEL proposes to upgrade the existing AHP MCC cum control room(near chimney) with additional floors for the new proposed AHP MCC cum control room	Shall be decided during detail engg.