

Letter No.....

Dated.....

Tender Amendment Notice

Ref: NIT No. 053/CIVIL/W/TVNL/RAN/2016-17, Due date: 03.04.2017

Intermediate Silo mentioned in the clause nos. 4.02 (5), 8.02.03 and 1.2 of section V of Volume- IIA (Technical specification for design, supply & installation of Dry Fly Ash collection and disposal system at TTPS, Lalpania) of tender documents is hereby amended to the following extent:

Structural steel Intermediate Silos on RCC foundation may be allowed in place of RCC Intermediate Silos for SILO system of unit no. 1 & 2 against referred NIT.

All other terms & conditions of the NIT shall remain unchanged.

Sd/-
(R. Ranjan)
Electrical Suptd. Engineer (C&M)